



PROPERLY INSTALLED CORPORATION STOP, SHOWING GOOSE NECK IN SERVICE PIPE. SERVICE CLAMPS OR SADDLES TO BE USED ON ALL PVC OR FIBERGLASS COMPOSITE PIPE MAINS.

- NOTE:
1. WATER SERVICE LINES SHALL HAVE A MINIMUM COVER OF SIX (6) FEET MEASURED FROM THE EXISTING GROUND SURFACE, EXCEPT THAT COVER SHALL BE MEASURED FROM CENTER STREET GRADE WHEN SERVICE LINES ARE LAID TO A STREET SIDE WHICH HAS AN UPHILL SLOPE.
  2. WATER SERVICE LINES SHALL BE INSTALLED WHERE SHOWN ON THE DRAWINGS OR AS SPECIFIED.
  3. BEDDING SHALL BE 1" 0 MAXIMUM WITHIN 6" OF SERVICE PIPE.

\\Fserver\CAD\2007\07-075 WWSO\dwg\STD DWGS.dwg, WATER SERVICE CONNECTION, 10/28/2009 11:20:34 AM